

N 93-31448

TERMINOLOGY AND CONCEPTS OF CONTROL AND FUZZY LOGIC

Presented at
A Workshop on Fuzzy Control
Huntington Beach, CA
14 November 1990

Dr. Jack Aldridge, MDSSC- SSD (Houston)
Dr. Robert Lea NASA/JSC
Dr. Yashvant Jani Lincom Corp.
Dr. Jonathan Weiss MDSSC-SSD (Houston)

54-67
163078
P. 20

79

INTERNATIONAL PRESS

PURPOSES OF THIS TALK

MCDONNELL DOUGLAS


- Briefly review control history - how do ideas "fit together"
- Establish terminology of control theory and fuzzy logic to promote useful discussions
- Establish basic concepts ^{and issues} in both areas for the same purpose

CONTROL SYSTEMS

MCDONNELL DOUGLAS


- A means by which a variable quantity or a set of variable quantities is made to conform to a prescribed norm or to vary in a prescribed way
- May be operated by electrical means, mechanical means, hydraulic means, pneumatic means, or a combination

19



CONTROL THEORY WAS FORMULATED IN THREE PHASES

MCDONNELL DOUGLAS



ISSUES IN THE DESIGN OF A CONTROL SYSTEM

MCDONNELL DOUGLAS

Stability and Transient Response

Response Time or Bandwidth

Observability

Controllability

Continuous or Sampled Data

Single or Multiple Control Loops


Optimizing or "Near-Optimal" Control

Fixed, Adaptive, or Learning Control

EXAMPLES: INVERTED PENDULUM

MCDONNELL DOUGLAS

Control Problem:
Determine a control force, f , applied to the cart (pivot point) to keep pendulum at fixed angle



STATE SPACE CONTROL FOR INVERTED PENDULUM

MCDONNELL DOUGLAS

Equations of Motion

$$(M+m) \ddot{z} + m l \cos \theta \ddot{\theta} - m l \dot{\theta}^2 \sin \theta = f$$

$$m l \cos \theta \ddot{z} + m l^2 \ddot{\theta} - m g l \sin \theta = 0$$

State

$$\begin{bmatrix} z \\ v \\ \theta \\ \omega \end{bmatrix}$$

State Space Description of Dynamical System

$$\dot{z} = v$$

$$\dot{v} = \frac{m l \omega^2 \sin \theta}{M + m \sin^2 \theta} - \frac{m g \cos \theta \sin \theta}{M + m \sin^2 \theta} + \frac{f}{M + m \sin^2 \theta}$$

$$\dot{\theta} = \omega$$

$$\dot{\omega} = \frac{g \sin \theta (M + m)}{l (M + m \sin^2 \theta)} - \frac{m \omega^2 \sin \theta}{M + m \sin^2 \theta} - \frac{f \cos \theta}{M + m \sin^2 \theta}$$

LINEARIZED STATE SPACE

MCDONNELL DOUGLAS

$$\dot{z} = v$$


$$\dot{v} = \frac{f}{M} - \frac{mg\theta}{M}$$

$$\dot{\theta} = \omega$$

$$\dot{\omega} = \frac{(M+m)g\theta}{Ml} - \frac{f}{Ml}$$


DYNAMICAL SYSTEM MODEL FOR INVERTED PENDULUM ON A CART

==== MCDONNELL DOUGLAS =====



PROPORTIONAL-INTEGRAL-DERIVATIVE (PID) CONTROLLER

MCDONNELL DOUGLAS



Proportional component reduces error
Integral component reduces steady state offset
Derivative component anticipates and reduces overshoots

ADVANTAGES OF USING CONVENTIONAL CONTROL

MCDONNELL DOUGLAS

- **Technology is well established**
- **Many control problems are well approximated by linear plants or can be handled with adaptive systems that perturb controller parameters**
- **Technology is mathematically based allowing general properties of controllers to be explored by a theoretical approach**

PROBLEMS WITH STATE SPACE CONTROL?

MCDONNELL DOUGLAS

- **Model building stage is elaborate, iterative, error-prone, and time consuming**
- **A performance index that can be used for optimization must be formulated**
- **Actuators may be nonlinear**
- **Complex equipment may be poorly described by systems of differential equations but may be best described from experimental data or heuristics (rules of thumb or experience).**
- **Heuristics may be part of the operating procedure and may be based on mental models other than the physical models**

FUZZY CONTROLLER OVERVIEW

MCDONNELL DOUGLAS

Fuzzy Controller








DESIGNER-SUPPLIED
INFORMATION IS UNDERLINED

Fuzzy
Set
Membership
Functions

IF...THEN... Rules

Defuzzifier
Techniques

MAX
Centroid



Sensor
Inputs

Fuzzifier

Rule Processing

Defuzzifier


Control
Outputs

91


2-2

APPROACH (CONT.)

FUZZY PROCESSING



RULE: IF (PHI EQ PB AND PHI_DOT EQ ZO) THEN ACCELERATION IS NS
 MIN (μ_1, μ_2) IS APPLIED TO NS FUNCTION IN ACCELERATION




RULE BASE FOR FORCE ON INVERTED PENDULUM CART

MCDONNELL DOUGLAS

Fuzzy Table Inv Pend



		Angle				
		NB	NS	ZO	PS	PB
Angle Rate	PB	ZO	PB	PB	PB	PB
	PS	NB	ZO	PS	PB	PB
	ZO	NB	NS	ZO	PS	PB
	NS	NB	NB	NS	ZO	PB
	NB	NB	NB	NB	NB	ZO

Example Rule: IF Angle is PS AND Angle Rate is NS THEN Force is ZO




APPROACH (CONT.)

FUZZY PROCESSING



TWO RULES FIRE:

1. IF PHI IS PB AND PHI_DOT IS PS THEN ACCEL IS NS
2. IF PHI IS PB AND PHI_DOT IS PM THEN ACCEL IS NM




FUZZY RULE PROCESSING

MCDONNELL DOUGLAS

USE MAXIMUM FOR LOGICAL OR

IF ... THEN u is NS .3
IF ... THEN u is ZO .8
IF ... THEN u is PS .1
IF ... THEN u is PB .3



USE MINIMUM FOR LOGICAL AND

Rule: IF x1 is NS AND x2 is ZO
THEN u is PS

Facts:

x1 is NS 0.2


x2 is ZO 0.8 \Rightarrow u is PS 0.2

Other options exist for combining logical connectives but these preserve all results from normal set theory except exclusion law:
 $A \text{ AND NOT } A = \emptyset$

DEFUZZIFICATION


MCDONNELL DOUGLAS

MAX Procedure



8

Centroid Procedure



$$u_0 = \frac{\int u U du}{\int U du}$$

Indexed MAX or Centroid Procedure

Same as above except use only points $>$ threshold value

FUZZY CONTROLLER ADVANTAGES

MCDONNELL DOUGLAS

- **Can exploit heuristic knowledge of operation of controlled systems. This includes physical intuition.**
- **Can accommodate small changes in system or controller parameters. This are the aging effect and nonlinear effects such as flexibility of beams**
- **Experience has been that these techniques seem to handle nonlinearity well**
- **Tools have been developed to assist in studying and building fuzzy controllers in short times**
- **The development of fuzzy chips has provided computationally capable platforms on which to build the controller, independent of general purpose computers used for spacecraft control**

REMAINING ISSUES FOR FUZZY CONTROL

MC DONNELL DOUGLAS

- **Issues such as stability, observability, and controllability raised in servomechanism and state space control are not yet in comparable state of development. This may limit initial applicability to noncritical applications**
- **Definition of membership functions is arbitrary and controller designer dependent.**
- **Procedures for selecting membership functions and defuzzifier options are not firmly established in the control community**
- **There are limited sources for fuzzy control chips**