

Department of Property&Procurement

Government of the United States Virgin Islands 3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820



ST. CROIX FAX: 340.773.0986 | ST. THOMAS FAX: 340.774.9587

HTTP://DPP.VI.GOV

January 5, 2021

AMENDMENT EIGHT (8) IFB019DOEC21(C) Temporary Parking Lot at the Charles Harwood Modular Campus, St. Croix, U.S. Virgin Islands

INSERT

Question: Please confirm the aggregate base thickness required for the project?

Answer: Aggregate Base Course thickness for Asphalt Pavement is 12-inches. For sidewalks, ramps, cross gutters, curbs and gutters, is 4inches.

DELETE

Question: Please confirm the aggregate base thickness required for the project?

Answer: Please refer to 32 11 23-3 (3.2) of the technical specification document.

THE REMAINDER OF THIS PAGE INTENTIONALLY LEFT BLANK.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.